

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 402

Dated: 28/01/2026

It is to certified that an inspection team headed by: Ashok Kumar Sahoo Asst. Engineer
 (Name of the Officers with designation) from RWSS Aul
 (Name of Department/ Office) inspected the DPIS, UTKAL, Goudapatna, Aul Block
Kendrapara (Name & Address of the school) on 24/01/2026 (date of inspection),
 checked the water test report submitted by the school and found that the school has potable
 drinking water for students and staff of the institution and is having provision for running
 water in the toilets and maintaining hygienic sanitation condition in the school building & the
 campus as per norms prescribed by the Central/State/ U.T. Govt.
 The above is valid for a period of One - year.

Signature with Seal Ashok Kumar Sahoo
28/01/2026
Assistant Engineer
RWSS & S Section, AulName: Ashok Kumar SahooDesignation: Asst. Engineer RWSS Section, AulAssistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department:

RWSS, Section- AUL

To

DELHI PUBLIC INTERNATIONAL SCHOOL, UTKALGOUDAPATNA, KANTIPUR ROAD
AUL BLOCK, KENDRAPARA, PIN- 754219
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,
 translated notarized version in English be uploaded along with the original vernacular certificate as a
 single pdf.

**SUB-DIVISIONAL WATER TESTING LABORATORY, R.W.S.&S,
SUB-DIVISION, PATTAMUNDAI,
(NABL ACCREDITED)**

Phone -06729-291149 ; E-mail. - sdllabrwsspattamundai@gmail.com



WATER ANALYSIS REPORT

**TEST REPORT NO- SDWTLP-21
DATE OF ISSUE -20.02.2026**



TC-10687

Sample Particulars		Details of Sampling	
Name of the Customer :-	Delhi Public International School Utkal	Type of Source:-	Borewell
		Date of Sampling:-	19.02.2026
Sample Package Condition:- a) Quantity of Sample Received - 500ml b) Type of Container - pp		Sample receive date:- Vide letter No.	19.02.2026 / Vide letter No-165
		Sample Registration Date:-	19.02.2026
		Sampling Protocol:-	Samples are not collected by this laboratory.
		Sample Collected by:-	Delhi Public International School Utkal
		Sample Location:-	Loc- Aul,(Delhi Public International School Utkal).

TEST RESULT

Test Started on-		19.02.2026		Test Completed on-		19.02.2026	
Sl.	Test Parameters	Units	Results	Requirements IS 10500 : 2012		Test Method	
				Acceptable Limit	Permissible Limit in absence of alternate source		
1	pH	pH Unit	6.98	6.5 to 8.5	No relaxation	APHA 23 rd Ed. 4500-H ⁺ B (Electrometric Method)	
2	Elect. Conductivity	µmho/cm	1408	----	----	APHA 23 rd Ed. 2510 B (Laboratory Method)	
3	TDS Total Dissolved Solids (TDS)	mg/l	785.2	500	2000	APHA 23 rd Ed. 2017 : 2540 C (Total Dissolved Solids Dried at 180oC)	
4	Total Alkalinity (as CaCO ₃)	mg/l	256	200	600	APHA 23 rd Ed. 2320 B (Titration Method)	
5	Iron	mg/l	0.216	1.0	No relaxation	APHA 23 rd Ed. 3500 Fe B; (Phenanthroline Method)	
6	Turbidity	NTU	0.45	1.0	5.0	APHA 23 rd Ed. 2130 B (Nephelometric Method)	
7	Chloride	mg/l	260	250	1000	APHA 23 rd Ed. 4500 Cl- B (Argentometric Method)	
8	Total Hardness (as CaCO ₃)	mg/l	256	200	600	APHA 23 rd Ed. 2340 C (EDTA Titration Method)	
9	Calcium (as Ca)	mg/l	112.2	75	200	APHA 23 rd Ed. 3500 Ca B (EDTA Titrimetric Method)	
10	Magnesium (as Mg)	mg/l	48.6	30	100	APHA 23 rd Ed. 3500 Mg B (Calculation Method)	
11	Colour	Hazen Units	01	5	15	APHA 23 rd Ed. 2017 : 2120 B (Visual Comparison Method)	
12	Odour	Qualitative Observation	Agreeable	Agreeable	Agreeable	APHA 23 rd Ed. 2017 :2150 B (Threshold Odour Test)	
13	Taste	Qualitative Observation	Agreeable	Agreeable	Agreeable	APHA 23 rd Ed. 2017 : 2160 B (Flavor Threshold Test)	

Note :- The samples were tested with dilution.


Information on Test Report :

Results relates only to samples received in the Laboratory .

The test report shall not be reproduced except in full without written approval of SDWTLP .

APHA - American Public Health Association

Reviewed by


20-02-26
Technical Manager

***** End of Report*****

Quality Manager.

Sub-Divisional Water Testing Laboratory,
RWS&S, Sub- Division, Pattamundai
Authorised Signatory